

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

Dated :

It is certified that an inspection team headed by DR. PRAVEEN DIXIT (Name of Officer with Designation) From C.H.C. Shahabad (Chardoi) (Name of Department/ Office) inspected the D.M. INTERNATIONAL PUBLIC SCHOOL (Name & Address of the School) on 08/05/2026 (Date of Inspection) and on the basis of Water test Report (Attached) bearing No. 216 dated 29/04/2026 of DISTRICT LEVEL WATER ANALYSIS LABORATORY SHAHJAHANPUR (PHED Lab) certified that the D.M. INTERNATIONAL PUBLIC SCHOOL (Name of the School) has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per the norms prescribed by the Central/State/U.T Govt.

The above valid for a period of 1 Year.

Signature DR. PRAVEEN DIXIT
 Name : DR. PRAVEEN DIXIT
 Designation : हस्तक्षेपक
 Name & Address of the office / Department:

To,

D.M. INTERNATIONALPUBLIC SCHOOLSHAHABAD (CHARDOI)

(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies



WATER ANALYSIS REPORT

District Level Water Analysis Laboratory,
Uttar Pradesh Jal Nigam (Rural), Shahjahanpur

Address- Office of Executive Engineer, U.P. Jal Nigam (Rural),
B-2, Garden Estate (In Front of South city), Jalalabad Road, Shahjahanpur-242001



TC-17255

Report No.

216

Date:-

29.04.2026

Page No. 01

Basic Detail of Sample

Name of The Customer & Address

D.M. International Public School, Shahabad, Hardoi.

Water Source

Submersibil

Sample Code

C/26/04/P-216

Quantity of Sample

1 Ltr

Date of Sample Collection

27.04.2026

Receiving Date

27.04.2026

sample Collector

Mr. Vinod Kumar

Sample Depositor

Mr. Vinod Kumar

Contact Person By

Mr. Vinod Kumar

Analysis Start Date

27.04.2026

Analysis Completion Date

28.04.2026

Environmental Condition

Temperature

25.3 °C

Humidity

54 °C

Technical DATA of Analysis

Sr. N.	Analysed Parameter	Units	Ovserved Value	Specified Values as per BIS 10500:2012		Ref. Method of Analysis
				Acceptable Limit	Permissible Limit	
1	Turbidity	(NTU)*	0.438	1.0	5.00	IS 3025 (Part 10): 2023 (Nephelometric Method)
2	TDS	(Mg/L)*	228	500	2000	IS 3025 (Part 16): 2023 (Gravimetric Method)
3	pH (25°C)	-	7.436	6.5-8.5	No Relaxation	IS 3025 (Part 11): 2022
4	Chloride	(Mg/L)*	45.985	250	1000	IS 3025 (Part 32): 2023 (Argentometric Method)
5	Calcium (as Ca)	mg/l*	41.6	75	200	IS 3025 (Part 40): 2024 (Titration Method)
6	Magnesium (as Mg)	mg/l*	34.160	30	100	IS 3025 (Part 46): 2023 (EDTA Method)
7	Total Hardness	(Mg/L)*	244	200	600	IS 3025 (PART 21): 2023 (EDTA Method)
8	Total Alkalinity	(Mg/L)*	280	200	600	IS 3025 (PART 23): 2023 (Titration Method)
9	Fluoride	(Mg/L)*	0.162	1.0	1.5	APHA 24rd Edition-4500-F method C (Electrode method) 2023
10	Taste		Agreeable	Agreeable	Agreeable	IS 3025(PART 8) 2023
11	Odour		Agreeable	Agreeable	Agreeable	IS 3025(Part 5) 2018
12	Colour	HU*	5	5 HU	15 HU	APHA 24rd Edition - 2120- Colour Method B (Platinum Cobalt Visual Comparison) 2023


Note:

1. Certificate refers only to the Particular sample submitted for testing.
2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from The Head of Laboratory.
3. The test results reported in this certificate are valid at the time of and under the stated conditions of measurements.
4. Sample will be stored up to 7 days (in case of non perishable items only) from the date of issue of tests report unless otherwise specified.
5. Parameters above permissible limit This are written in Bold.

(Signature)

(Dharmendra Kumar Verma)
Technical Manager (Rural)

END OF REPORT





District Level Water Analysis Laboratory,
U.P. Jal Nigam (Rural), Shahjahanpur
Office of Executive Engineer, U.P. Jal Nigam (Rural), Shahjahanpur
B-2 Garden Estate (In Front Of South City) Jalalabad Road, Shahjahanpur-242001

Report No. 1

Date :

29.04.2026

Page No

01

Bacteriological Test Report

Customer Details

Office Name & Address

Office of Executive Engineer, U.P. Jal Nigam (Rural), Shahjahanpur
B-2 Garden Estate (In Front Of South City) Jalalabad Road, Shahjahanpur-242001

Ref. Letter No & Date

Basic details of sample

District	Hardoi	Block	
Nagar/Gram Panchayat		Address	D.M. International Public School, Shahabad, Hardoi.
Habitation		Location	D.M. International Public School, Shahabad, Hardoi.
Water Source	Submersibil	Sample No.	B/26/04/P-1
Quality of Sample	250ml	Date of S.C.	24.04.2026
Receiving Date	24.04.2026	S. Collector	Mr. Vinod Kumar
Sample Depositer	Mr. Vinod Kumar	Analysis Completion Date	25.04.2026
Analysis Start Date	24.04.2026		

Temperature

$25 \pm 3^{\circ}C$

Environmental Condition

Relative Humidity

$50 \pm 15^{\circ}C$

Technical Data of Analysis

S.no.	Analysed parameters	Unit of Measurement	Observed Value	Specified Values as per IS 10500:2012		Ref. Method of Analysis
				Acceptable Limit	Permissible Limit in absence of alternate source	
1	2		3	4	5	6
1	Total Coliform	CFU/100ml.	0.0	Shall not be detectable in any 100 ml sample	No Relaxation	MFT TECHNIQUE IS 15185:2016
2	E. Coli	CFU/100ml.	0.0	Shall not be detectable in any 100 ml sample	No Relaxation	MFT TECHNIQUE IS 15185:2016

Note

1. This Certificate refers only to the particular sample(s) submitted for testing.
2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from Head of Laboratory.
3. The test results reported in this certificate are valid at the time of and under the stated conditions of measurements.
4. Sample will be stored up to 2 days (in case of non perishable items only) from the date of issue of tests reports unless otherwise specified.

Result

Satisfactory

End Of Test Report

Authorized Signatory

